

FOUNDATION CALCULATION SHEET

One-Stop Solution for Foundation



TITLE		DESCRIPTION				
PROJECT/JOB NO.		Revise F2-F3				
PROJECT/JOB NAME		7.5 MW. Power Plant Stream Turbine				
CLIENT NAME		SAHAGREEN FOREST				
SITE NAME		KAMPANGPET				
DOCUMENT NO.						
REFERENCE NO.						
STRUCTURE NAME		Revise F2-F3				
LOAD COMBINATION GROUP						
REV	DATE	DESCRIPTION	PREP'D	CHK'D	APPR'D	APPR'D

Project Na. : 7.5 MW. Power Plant Stream..

Client : SAHAGREEN F...

FOUNDATION LISTS

[illegible]



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 2

CONTENTS

1. GENERAL

- 1.1 CODE & STANDARD
- 1.2 MATERIALS & UNIT WEIGHT
- 1.3 SUBSOIL CONDITION & SAFETY FACTORS
- 1.4 LOAD COMBINATION

2. DRAWING

- 2.1 LOCATION PLAN & DETAIL SKETCH

3. FRAME ANALYSIS

- 3.1 FRAME DRAWING
- 3.2 FRAME ANALYSIS DATA

4. FOUNDATION DATA

- 4.1 FOOTING AND SECTION DATA
- 4.2 PIER DATA
- 4.3 LOAD CASE
- 4.4 LOAD COMBINATION

5. CHECK OF STABILITY

- 5.1 CHECK OF PILE REACTION

6. DESIGN OF FOOTING

- 6.1 DESIGN MOMENT AND SHEAR FORCE
- 6.2 REQUIRED REINFORCEMENT
- 6.3 ONE WAY SHEAR FORCE
- 6.4 TWO WAY SHEAR FORCE
- 6.5 PILE PUNCHING SHEAR FORCE

7. DESIGN OF TIE-GIRDER

- 7.1 FORMULA
- 7.2 GEOMETRY AND MATERIALS
- 7.3 MEMBER FORCE
- 7.4 REQUIRED REINFORCEMENT
- 7.5 ONE WAY SHEAR



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 3

1. GENERAL

1.1 CODE & STANDARD

Items	Description
Design Code	American Concrete Institute (ACI 318) [Metric]
Horizontal Force for Wind	UNIFORM BUILDING CODE (UBC-1997)
Horizontal Force for Seismic	UNIFORM BUILDING CODE [UBC-1997]
Unit System	Input : MKS, Output : MKS, Calculation Unit : IMPERIAL

1.2 MATERIALS & UNIT WEIGHT

Items	Value
Concrete (f'c : compressive strength)	280.000 kgf/cm ²
Lean Concrete (Lf'c : compressive strength)	240.000 kgf/cm ²
Reinforcement (#3 ~ #5 , yield strength)	4000.000 kgf/cm ²
Reinforcement (#6 ~ , yield strength)	4000.000 kgf/cm ²
Rs (Soil unit weight)	1.700 ton/m ³
Rc (Concrete unit weight)	2.400 ton/m ³
Es (Steel Modulus of Elasticity)	2.040 × 10 ⁶ kgf/cm ²
Ec (Concrete Modulus of Elasticity)	252976.800 kgf/cm ²

- Pile Capacity

Items	Value
Pile Name	PHC-12
Footing List	F-3, F-2
Diameter	300 mm
Length	14 m
Thick	10 mm
Shape	Square
Capacity (Ha , Ua , Va)	2 , 15 , 30 tonf

1.3 SUBSOIL CONDITION & SAFETY FACTORS

Items	Description
Allowable Increase of Soil (Wind)	33.33 %
Allowable Increase of Soil (Seismic)	33.33 %
Allowable Increase of Soil (Test)	20 %
Allowable Increase of Pile Horizontal (Wind)	33.33 %
Allowable Increase of Pile Horizontal (Seismic)	33.33 %
Allowable Increase of Pile Horizontal (Test)	20 %
Allowable Increase of Pile Vertical (Wind)	33.33 %
Allowable Increase of Pile Vertical (Seismic)	33.33 %
Allowable Increase of Pile Vertical (Test)	20 %
Allowable Increase of Pile Uplift (Wind)	0 %
Allowable Increase of Pile Uplift (Seismic)	0 %
Allowable Increase of Pile Uplift (Test)	0 %



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 4

Safety factor against overturning for OVM1(FO1)	1.5
Safety factor against overturning for OVM2(FO2)	1.5
Safety factor against overturning for OVM3(FO3)	1.5
Safety factor against overturning for OVM4(FO4)	1.9
Safety factor against sliding for the SL1(FS1)	1.5
Safety factor against sliding for the SL2(FS2)	1.8
Safety factor against sliding for the SL3(FS3)	1.5
Safety factor against sliding for the SL4(FS4)	1.5
Friction factor (μ)	.35

1.4 LOAD COMBINATION

Index	Load Case Name	Load Case Description
1	SW	SELF WEIGHT
2	DL	DEAD LOAD

1.4.1 Group - F-3

Footing List = F-3


Comb . ID	Load Combination for Reinforcement
1	1.0 SW + 1.0 DL

1.4.2 Group - F-2

Footing List = F-2


Comb . ID	Load Combination for Reinforcement
1	1.0 SW + 1.0 DL

2. DRAWING




REFERENCE DWGS						
NO.	DWG NO.			DWG TITLE		
NOTES						
* OUTPUT UNIT : mm						
7.5 MW. Power Plant Stream Turbine PROJECT						
FOUNDATION LOCATION PLAN Revise F2-F3						
SQUAD CHECK						
	PROCESS	PIPING	VESSELS	STRUCT.	ELEC.	INST.
SCALE		JOB NO.		MICROFILM NO.		
AS SHOWN		Revise F2-F3				

2.2 DETAIL SKETCH




OUTPUT UNIT : mm



FOUNDATION PLAN

REV.	DATE	DESCRIPTION	DRWN	CHKD	APPD	APPD	APPD	APPD	APPD



REFERENCE DWGS						
NO.	DWG NO.	DWG TITLE				
NOTES						
* PILE 2-??300 PHC-12 * ANCHOR BOLT 1X4-M12 ANC. BOLTS (TYPE TYPE L) * OUTPUT UNIT : mm						
7.5 MW. Power Plant Stream Turbine PROJECT						
FOUNDATION DETAIL FOR						
F-3						
SQUAD CHECK						
	PROCESS	PIPING	VESSELS	STRUCT.	ELEC.	INST.
SCALE		JOB NO.		MICROFILM NO.		
PD	AS SHOWN		Revise F2,F3			



REINFORCEMENT PLAN


REV.	DATE	DESCRIPTION	DRWN	CHKD	APPD	APPD	APPD	APPD	APPD

REFERENCE DWGS						
NO.	DWG NO.	DWG TITLE				
NOTES						
* PILE 2-??300 PHC-12 * ANCHOR BOLT 1X4-M12 ANC. BOLTS (TYPE TYPE L) * OUTPUT UNIT : mm						
7.5 MW. Power Plant Stream Turbine PROJECT						
FOUNDATION DETAIL FOR						
F-3						
SQUAD CHECK						
	PROCESS	PIPING	VESSELS	STRUCT.	ELEC.	INST
SCALE		JOB NO.		MICROFILM NO.		
PD AS SHOWN	Revise F2-F3					




F-3	Item No.	
<div data-bbox="129 172 694 821"><p>1</p><p>400</p><p>400</p><p>25 TYP.</p><p>#3</p><p>#8</p><p>30 GR.</p><p>75 PROJ.</p><p>1500</p><p>#8</p><p>#3 @200</p><p>100</p><p>18.75</p><p>18.75</p><p>362.5</p><p>18.75</p><p>18.75</p><p>362.5</p><p>25</p><p>50</p></div>		


2.2 DETAIL SKETCH




OUTPUT UNIT : mm




FOUNDATION PLAN



FOOTING REINF. PLAN



SECTION



PEDESTAL

REFERENCE DWGS

NO.	DWG NO.	DWG TITLE

NOTES

- * PILE
5-??300 PHC-12
- * ANCHOR BOLT
1X4-M12 ANC. BOLTS (TYPE TYPE L)
- * OUTPUT UNIT : mm

7.5 MW. Power Plant Stream Turbine PROJECT

FOUNDATION DETAIL FOR
F-2

SQUAD CHECK						
	PROCESS	PIPING	VESSELS	STRUCT.	ELEC.	INST.

SCALE		JOB NO.	MICROFILM NO.
AS SHOWN		Revise F2-F3	

3. FRAME ANALYSIS

3.1 FRAME DRAWING

Sturcture 1



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 14

3.2 FRAME ANALYSIS DATA

3.2.1 Structure 1

» Member and Force

Unit (tonf,tonf-m)

Member	LC#		Axial	Shear-Y	Shear-Z	Torsion	Moment-Y	Moment-Z
1	1	i	-114.5	0	-.714	0	0	0
		j	-114.5	0	-.714	0	.571	0
2	1	i	-113.9	0	-.714	0	.571	0
		j	-113.9	0	-.714	0	.785	0
3	1	i	-112.5	0	0	0	0	0
		j	-112.5	0	0	0	0	0
4	1	i	-235.4	0	.714	0	0	0
		j	-235.4	0	.714	0	-.571	0
5	1	i	-234.8	0	.714	0	-.571	0
		j	-234.8	0	.714	0	-.785	0
6	1	i	-233.3	0	0	0	0	0
		j	-233.3	0	0	0	0	0
7	1	i	-.714	-1.44	0	0	0	-.785
		j	-.714	1.44	0	0	0	-.785

» Support Reactions

Unit (tonf,tonf-m)

Joint	LC#	Force-X	Force-Y	Force-Z	Moment-X	Moment-Y	Moment-Z
1	1	0	.714	114.52	0	0	0
2	1	0	-.714	235.37	0	0	0



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..


Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 15

4. FOUNDATION DATA

4.1 FOOTING AND SECTION DATA



» Section Data

(mm)	Ft.Name	Direction	Ft. Volume	Soil Volume	Pier Wt
	F-3	All Direct	1.489 m ³	0.851 m ³	0.576 tonf
	Sec.Name	Section Area	Ft. Weight	Soil Weight	Total Weight
	S1	1.861 m ²	3.574 tonf	1.447 tonf	5.596 tonf




Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3


Client : SAHAGREEN F...

Page 16



- The Origin coordinate
— The Center of Gravity (0,0) mm
— The Center of Pile (90,180) mm

Ft. Name	F-2
Ft. Type	ISO
Area	4.860 m ²
Ft. Thickness	800.00 mm
Ft. Volume	3.888 m ³
Ft. Weight	9.331 tonf
Soil Height	500.00 mm
Soil Volume	2.350 m ³
Soil Weight	3.995 tonf
Buoyancy	Not Consider
Self Weight (except Pr.SW)	13.326 tonf



Section Data

Ft.Name	Direction	Ft. Volume	Soil Volume	Pier Wt
F-2	All Direct	3.888 m ³	2.350 m ³	0.576 tonf
Sec.Name	Section Area	Ft. Weight	Soil Weight	Total Weight
S1	4.860 m ²	9.331 tonf	3.995 tonf	13.902 tonf

4.2 PIER DATA

Off X , Off Y is offset position from the Center of the footing

If Pier Shape is Circle or Circle wall, PI is a Diameter. and Pw is a Inner Diameter


Area is pier concrete area

Weight is pier and inner soil weight in case circle wall except Tank1 Type(Circle Ring Footing Shape)

Unit(Length : mm , Weight : tonf , Area : m²)

Ft.Name	Pr.Name	Shape	PI	Pw	Ph	Area	Weight	Off X	Off Y
F-3	1	Rectangle	400.000	400.000	1500.000	0.160	0.576	0.000	20.575
F-2	2	Rectangle	400.000	400.000	1500.000	0.160	0.576	0.000	0.000

4.3 LOAD CASE



Input the point loads in the global coordinate system direction. Positive directions of moments (shown in the sketch) are based on the right hand rule.



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 17

Index	Load Case Name	Load Case Description
1	SW	SELF WEIGHT
2	DL	DEAD LOAD

Unit(tonf , tonf-m)

Ft.Name	Pr.Name	Load Case	Fx	Fy	Fz	Mx	My
F-3	1	1	0	0	-.58	0	0
		2	0	0	-112.5	0	0
		Footing SW	0.000	0.000	-5.020	0.000	0.000
F-2	2	1	0	0	-.58	0	0
		2	0	0	-233.35	0	0
		Footing SW	0.000	0.000	-13.326	0.000	0.000

4.4 LOAD COMBINATION

<p>In Pier Top without Self Weight</p>	<p>In Footing Bottom with Pier Self Weight, But without Footing Self Weight, (Frame Analysis)</p>	<p>In Footing Bottom Center with Pier & Footing Self Weight & Soil Weight, Case PileType in centroid of Pile Group Case NonPileType in centroid of Footing</p>
--	---	--

4.4.1 Load Combination in Pier Top (Without SW)

» Group 1 - F-3

Unit(tonf , tonf-m)

Ft.Name	Pr.Name	L.Comb.	ΣFx	ΣFy	ΣFz	ΣMx	ΣMy
F-3	1	1	0.000	0.000	-112.500	0.000	0.000

» Group 2 - F-2

Unit(tonf , tonf-m)

Ft.Name	Pr.Name	L.Comb.	ΣFx	ΣFy	ΣFz	ΣMx	ΣMy
F-2	2	1	0.000	0.000	-233.355	0.000	0.000

4.4.2 Load Combination in Footing Bottom (With Pier SW)

» Group 1 - F-3

Unit(tonf , tonf-m)

Ft.Name	Pr.Name	L.Comb.	ΣFx	ΣFy	ΣFz	ΣMx	ΣMy
F-3	1	1	0.000	-0.714	-114.520	0.000	0.000

» Group 2 - F-2

Unit(tonf , tonf-m)

Ft.Name	Pr.Name	L.Comb.	ΣFx	ΣFy	ΣFz	ΣMx	ΣMy
F-2	2	1	0.000	0.714	-235.370	0.000	0.000



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 18

4.4.3 Load Combination in Footing Bottom Center (With Pier & Footing SW)

► Load Combination of Elastic Condition

There is no Load Combination

► Load Combination of Ultimate Condition

Ⓟ : PileType

Group 1 - F-3

- C.G. of Load is coordinate from left bottom. Unit : mm

Unit(tonf , tonf-m)

Ft.Name	Sec.Nam	L.Comb.	ΣF_x	ΣF_y	ΣF_z	ΣM_x	ΣM_y	C.G. of Loads
F-3 Ⓟ	S1	1	0.000	-0.714	-119.540	17.365	26.897	900.0 , 646.1


Group 2 - F-2

- C.G. of Load is coordinate from left bottom. Unit : mm

Unit(tonf , tonf-m)

Ft.Name	Sec.Nam	L.Comb.	ΣF_x	ΣF_y	ΣF_z	ΣM_x	ΣM_y	C.G. of Loads
F-2 Ⓟ	S1	1	0.000	0.714	-248.696	44.765	-22.383	900.0 , 1350.0

4.4.4 Pile Reaction Table



Footing Name	F-3
Section Name	-
Pile Name	PHC-12
Pile Shape	Square
Pile Number	2 EA
Pile Diameter	300 mm
LC Type	Stability
<div> <div>--- Origin Point (0,0) mm</div> <div>— The Center of Gravity (0,0) mm</div> <div>— The Center of Pile (-225,165) mm</div> </div>	




Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 19




Footing Name	F-3
Section Name	S1
Pile Name	PHC-12
Pile Shape	Square
Pile Number	2 EA
Pile Diameter	300 mm
LC Type	Reinforce
<p>--- Origin Point (0,0) mm</p> <p>--- The Center of Gravity (0,0) mm</p> <p>--- The Center of Pile (-225,165) mm</p>	

· LC : 1, (1.0 SW + 1.0 DL)

Unit (mm,tonf)

No.	Name	Pile Geometry		Bi-Axial	Shear (Hor)	Ra	Ua	Ha
		X	Y	XY-Dir.	XY-Dir.			
1	PHC-12	-450	-285	19.29	.36	30	15	2
2	PHC-12	0	615	100.25	.36	30	15	2



Footing Name	F-2
Section Name	-
Pile Name	PHC-12
Pile Shape	Square
Pile Number	5 EA
Pile Diameter	300 mm
LC Type	Stability
<p>--- Origin Point (0,0) mm</p> <p>--- The Center of Gravity (0,0) mm</p> <p>--- The Center of Pile (90,180) mm</p>	




Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 20



Footing Name	F-2
Section Name	S1
Pile Name	PHC-12
Pile Shape	Square
Pile Number	5 EA
Pile Diameter	300 mm
LC Type	Reinforce

- Origin Point (0,0) mm
- The Center of Gravity (0,0) mm
- The Center of Pile (90,180) mm

· LC : 1, (1.0 SW + 1.0 DL)

Unit (mm,tonf)

No.	Name	Pile Geometry		Bi-Axial	Shear (Hor)	Ra	Ua	Ha
		X	Y	XY-Dir.	XY-Dir.			
1	PHC-12	450	900	27.24	.14	30	15	2
2	PHC-12	-450	900	47.96	.14	30	15	2
3	PHC-12	-450	0	65.73	.14	30	15	2
4	PHC-12	450	0	45	.14	30	15	2
5	PHC-12	450	-900	62.77	.14	30	15	2



**Calculation Sheet
of
Foundation**

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 21

5. CHECK OF STABILITY

There is no Static LoadCombination



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 22

6. DESIGN OF FOOTING

6.1 DESIGN MOMENT AND SHEAR FORCE

Footing design is in accordance with ultimate strength method at footing bottom.

Calculated total pier load as

$$\Sigma Q = \Sigma F_z - \text{Self Weight Factor} \times (\text{Soil Weight} + \text{Footing Weight})$$

Ft.Name : Footing Name , Sec.Name : Strip Name for Footing Reinforcement Design

Dir. : Direction , L.Comb. : Load Combination Index , Sl or Sw : Strip X or Y width

6.1.1 Data

Group 1 - F-3

Unit(mm , tonf , tonf-m)

Ft.Name	Sec.Nam	Dir.	L.Comb.	Fl or Fw	Sl or Sw	ΣF_z	ΣM	ΣQ
F-3φ	S1	X	1	2170.00	2170.00	119.540	26.90	114.520
	S1	Y	1	2170.00	2170.00	119.540	17.365	114.520

Group 2 - F-2

Unit(mm , tonf , tonf-m)

Ft.Name	Sec.Nam	Dir.	L.Comb.	Fl or Fw	Sl or Sw	ΣF_z	ΣM	ΣQ
F-2φ	S1	X	1	1800.00	2700.00	248.696	-22.38	235.370
	S1	Y	1	2700.00	1800.00	248.696	44.765	235.370

6.1.2 Design Parameters

Yield Strength - #3 ~ #5 : f_{y1} , #6 ~ : f_{y2}

f_{cl} : Clear Cover for edge of footing reinforcement

f_{clt} : Clear Cover for top of footing reinforcement

f_{pcb} : Clear Cover for bottom of footing reinforcement (Pile Foundation)

Loc. : Location of Critical Point from left side of footing

Unit(kgf/cm²,mm)

ϕ (Flexure)	ϕ (Shear)	f'_c	f_{y1}	f_{y2}	f_{cl}	f_{clt}	f_{pcb}
.85	.8	280.00	4000.00	4000.00	50.0	50.0	50.0



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 23

6.2 REQUIRED REINFORCEMENT

6.2.1 Reinforcement Formula

- Shrinkage and temperature reinforcement ---- ACI CODE 7.12.2

$A_s \geq \text{fac} \cdot b \cdot h$, fac = following

Area of shrinkage and temperature reinforcement shall provide at least the following ratio of reinforcement area to gross concrete area, but not less than 0.0014

(a) Slabs where Grade 40 or 50 deformed bars are used0.0020

(b) Slabs where Grade 60 deformed bars or welded wire reinforcement are used.....0.0018

(c) Slabs where reinforcement with yield stress exceeding 60,000 psi measured at a yield strain of 0.35 percent is used $\frac{0.0018 \times 60,000}{f_y}$

- Required Reinforcement by Analysis

$$A_s \geq A_{s2}$$

- At every section of flexural members where tensile reinforcement is required

$$A_s \geq A_{s5} \geq A_{s4} \quad \text{---- ACI Eq (10-3)}$$

- The requirements of Eq (10-3) need not be applied, if every section A_s provided is at least one -third greater then that required by analysis ---- ACI CODE 10.5.3

$$A_{s2} = \rho_{\text{req}} \cdot b \cdot d$$

$$A_{s3} = 1.333 \rho_{\text{req}} \cdot b \cdot d$$

$$A_{s4} = \frac{200}{f_y} \cdot b \cdot d$$

$$A_{s5} = \frac{3\sqrt{f_{ck}}}{f_y} \cdot b \cdot d$$

$$A_{s\text{max}} = 0.75 \rho_b \cdot b \cdot d$$

$$\rho_b = 0.85 \times \beta_1 \times \frac{f_{ck}}{f_y} \times \frac{0.003 \times E_s}{0.003 \times E_s + f_y}$$

$$\text{Selected } A_s = \text{Max} (A_{s1} , A_{s2} , \text{Min} (A_{s3} , \text{Max} (A_{s4} , A_{s5})))$$

If Selected $A_s < \text{Using } A_s < A_{s\text{max}}$, then OK!!

Note : The reinforcement is calculated bases on the maximum moment under the foundation in each direction.

But, the 'ISO', 'OCT', 'HEX', 'COMB', 'TANK1' foundations are calaulated as face pier

Where,

$$R_n = \frac{M_u}{\phi b d^2} , \phi = .85 , \rho_{\text{req}} = \frac{0.85 \cdot f_{ck}}{f_y} \times \left(1 - \sqrt{1 - \frac{2R_n}{0.85 f_{ck}}} \right)$$

6.2.2 Check of Footing Reinforcement

Group 1 - F-3

● Footing Name : F-3 GroupType : Irregular

- X direction (All Width)

Sec.Name	L.Comb.	Using Bar (mm)	Loc. (m)	Width b (m)	d (cm)	A_s (cm ²)
S1	1 top	9 - #8 @ 200	0.900	1.559	73.730	45.604
	1 botom	9 - #8 @ 200	0.900	1.559	73.730	45.604

Sec.Name	L.Comb.	Mu (tonf-m)	Rn	ρ -Req
S1	1 top	-	-	-
	1 bottom	-	-	-

Sec.Name	L.Comb.	A_{s1} (cm ²)	A_{s2} (cm ²)	A_{s3} (cm ²)	A_{s4} (cm ²)	A_{s5} (cm ²)	$A_{s\text{max}}$ (cm ²)
S1	1 top	11.224	-	-	40.403	38.246	263.643
	1 bottom	11.224	-	-	40.403	38.246	263.643



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 24

Sec.Name	L.Comb.		Using As(cm ²)	Select As(cm ²)	Result
S1	1	top	45.604	11.224	OK
	1	bottom	45.604	11.224	OK

- Y direction (All Width)

Sec.Name	L.Comb.		Using Bar (mm)	Loc. (m)	Width b (m)	d (cm)	As (cm ²)
S1	1	top	10 - #8 @ 200	0.320	1.800	71.190	50.671
	1	bottom	7 - #8 @ 200	0.847	1.192	71.190	35.470

Sec.Name	L.Comb.		Mu (tonf-m)	Rn	ρ-Req
S1	1	top	-	-	-
	1	bottom	15.947	3.106	0.0008

Sec.Name	L.Comb.		As ₁ (cm ²)	As ₂ (cm ²)	As ₃ (cm ²)	As ₄ (cm ²)	As ₅ (cm ²)	As _{max} (cm ²)
S1	1	top	12.960	-	-	45.046	42.641	293.941
	1	bottom	8.582	6.632	8.841	29.830	28.237	194.649

Sec.Name	L.Comb.		Using As(cm ²)	Select As(cm ²)	Result
S1	1	top	50.671	12.960	OK
	1	bottom	35.470	8.841	OK

Group 2 - F-2
☒ Footing Name : F-2 GroupType : Isolated

- X direction (All Width)

Sec.Name	L.Comb.		Using Bar (mm)	Loc. (m)	Width b (m)	d (cm)	As (cm ²)
S1	1	top	14 - #8 @ 200	0.900	2.700	73.730	70.939
	1	bottom	14 - #8 @ 200	1.100	2.700	73.730	70.939

Sec.Name	L.Comb.		Mu (tonf-m)	Rn	ρ-Req
S1	1	top	-	-	-
	1	bottom	31.087	2.492	0.0006

Sec.Name	L.Comb.		As ₁ (cm ²)	As ₂ (cm ²)	As ₃ (cm ²)	As ₄ (cm ²)	As ₅ (cm ²)	As _{max} (cm ²)
S1	1	top	19.440	-	-	69.980	66.244	456.642
	1	bottom	19.440	12.467	16.618	69.980	66.244	456.642

Sec.Name	L.Comb.		Using As(cm ²)	Select As(cm ²)	Result
S1	1	top	70.939	19.440	OK
	1	bottom	70.939	19.440	OK

- Y direction (All Width)

Sec.Name	L.Comb.		Using Bar (mm)	Loc. (m)	Width b (m)	d (cm)	As (cm ²)
S1	1	top	10 - #8 @ 200	1.350	1.800	71.190	50.671
	1	bottom	10 - #8 @ 200	1.550	1.800	71.190	50.671

Sec.Name	L.Comb.		Mu (tonf-m)	Rn	ρ-Req
S1	1	top	-	-	-
	1	bottom	49.739	6.415	0.0016



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 25

Sec.Name	L.Comb.		As ₁ (cm ²)	As ₂ (cm ²)	As ₃ (cm ²)	As ₄ (cm ²)	As ₅ (cm ²)	As _{max} (cm ²)
S1	1	top	12.960	-	-	45.046	42.641	293.941
	1	bottom	12.960	20.834	27.772	45.046	42.641	293.941

Sec.Name	L.Comb.		Using As(cm ²)	Select As(cm ²)	Result
S1	1	top	50.671	12.960	OK
	1	bottom	50.671	27.772	OK



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 26

Title

Bending Moment Diagram

Foundation name	F-3	Section name	S1	Direction	X	L/C ID	1		
Analysis Method Conventional Rigid Method with reaction (Method 1)									
ΣFz		-119.540 tonf		ΣMy		26.897 tonf-m		Moment inertia	0.3030 m ⁴
Area		1.861 m ²		Contact Area		Critical Point Method			Maximum Point
Critical Value Mu _{bottom} = 0 tonf-m , Mu _{top} = 0 tonf-m									





Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 27



Title

Bending Moment Diagram

Foundation name	F-3	Section name	S1	Direction	Y	L/C ID	1
Analysis Method Conventional Rigid Method with reaction (Method 1)							
ΣF_z	-119.540 tonf	ΣM_x	17.365 tonf-m	Moment inertia		0.3030 m ⁴	
Area	1.861 m ²	Contact Area		Critical Point Method		Maximum Point	
Critical Value Mu _{bottom} = 15.947 tonf-m , Mu _{top} = 0 tonf-m							



[Loading]





Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 28


Title

Bending Moment Diagram


Foundation name	F-2	Section name	S1	Direction	X	L/C ID	1		
Analysis Method Conventional Rigid Method with reaction (Method 1)									
ΣF_z		-248.696 tonf		ΣMy		-22.383 tonf-m		Moment inertia	1.3122 m ⁴
Area		4.860 m ²		Contact Area		Critical Point Method			Maximum Point
Critical Value		Mu _{bottom} = 31.087 tonf-m , Mu _{top} = 0 tonf-m							



[Loading]



414.49



414.49

[tonf , tonf/m]

[B.M.D]

-31.1
-23.3
-15.5
-7.8
0
7.8
15.5
23.3
31.1



31.09

[tonf-m]

[B/L.M.D]

-11.5
-8.6
-5.8
-2.9
0
2.9
5.8
8.6
11.5



11.51

[tonf-m / ft]



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 29

Title

Bending Moment Diagram

Foundation name	F-2	Section name	S1	Direction	Y	L/C ID	1
Analysis Method Conventional Rigid Method with reaction (Method 1)							
ΣF_z	-248.696 tonf	ΣM_x	44.765 tonf-m	Moment inertia	2.9525 m ⁴		
Area	4.860 m ²	Contact Area		Critical Point Method	Maximum Point		
Critical Value	Mu _{bottom} = 49.739 tonf-m , Mu _{top} = 0 tonf-m						





Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 30

6.3 ONE WAY SHEAR FORCE

6.3.1 One-Way Shear Formula


ACI 318-05 CODE 11.3.1.1

- For members subject to shear and flexure only.
- $\phi V_c = .8 \cdot 2 \sqrt{f_{ck}} B'w d$ (eq 11-3)
- $V_u \leq \phi V_c$, then OK!!

6.3.2 Check of One-Way Shear

Group 1 - F-3

● Footing Name : F-3 GroupType : Irregular PileType : True



- X direction One-Way Shear (All Width)

Sec.Name	L.Comb.	Loc. (mm)	d (mm)	Bw (mm)	ϕV_c (tonf)	V_u (tonf)	Result
S1	1	1784	737.3	55.4	2.901	0	OK

- Y direction One-Way Shear (All Width)

Sec.Name	L.Comb.	Loc. (mm)	d (mm)	Bw (mm)	ϕV_c (tonf)	V_u (tonf)	Result
S1	1	1096	711.9	904.4	45.708	39.726	OK



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3


Client : SAHAGREEN F...

Page 31

Group 2 - F-2

● Footing Name : F-2 GroupType : Isolated PileType : True

Unit : mm



- X direction One-Way Shear (All Width)

Sec.Name	L.Comb.	Loc. (mm)	d (mm)	Bw (mm)	ϕV_c (tonf)	V_u (tonf)	Result
S1	1	1190	737.3	2700	141.319	124.349	OK

- Y direction One-Way Shear (All Width)

Sec.Name	L.Comb.	Loc. (mm)	d (mm)	Bw (mm)	ϕV_c (tonf)	V_u (tonf)	Result
S1	1	2090	711.9	1800	90.967	71.056	OK



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 32

Title

Shear Force Diagram

Foundation name	F-3	Section name	S1	Direction	X	L/C ID	1
Analysis Method	Conventional Rigid Method with reaction (Method 1)						
ΣF_z	-119.540 tonf	ΣM_y	26.897 tonf-m	Moment inertia	0.3030 m ⁴		
Area	1.861 m ²	Contact Area		Critical Point Method	Maximum Point		
Critical Value	Vu = 0 tonf						





Calculation Sheet of Foundation

Project No. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 33

Title

Shear Force Diagram


Foundation name	F-3	Section name	S1	Direction	Y	L/C ID	1
Analysis Method Conventional Rigid Method with reaction (Method 1)							
ΣF_z	-119.540 tonf	ΣM_x	17.365 tonf-m	Moment inertia		0.3030 m ⁴	
Area	1.861 m ²	Contact Area		Critical Point Method		Maximum Point	
Critical Value		Vu = -39.726 tonf					




[Loading]



[S.F.D]



[S/L.F.D]





Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 34

Title

Shear Force Diagram

Foundation name	F-2	Section name	S1	Direction	X	L/C ID	1		
Analysis Method Conventional Rigid Method with reaction (Method 1)									
ΣFz		-248.696 tonf		ΣMy		-22.383 tonf-m		Moment inertia	1.3122 m ⁴
Area		4.860 m ²		Contact Area		Critical Point Method			Maximum Point
Critical Value		Vu = -124.349 tonf							





Calculation Sheet of Foundation

Project No. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3



Client : SAHAGREEN F...

Page 35

Title

Shear Force Diagram

Foundation name	F-2	Section name	S1	Direction	Y	L/C ID	1		
Analysis Method Conventional Rigid Method with reaction (Method 1)									
ΣF_z		-248.696 tonf		ΣM_x		44.765 tonf-m		Moment inertia	2.9525 m ⁴
Area		4.860 m ²		Contact Area		Critical Point Method			Maximum Point
Critical Value		Vu = -71.056 tonf							





Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 36

6.4 TWO WAY SHEAR FORCE

6.4.1 Two-Way Shear Formula

$$V_u = \Sigma F_z \cdot \text{Shade Ratio}$$

$$(a) \phi V_{c1} = .8 \cdot 2 \cdot (1 + 2/\beta_c) \sqrt{f_{ck}} b_o \cdot d \quad (\text{eq 11-33}) < V_{c1}$$

$$(b) \phi V_{c2} = .8 \cdot 2 \cdot (1 + \alpha_s d / 2 b_o) \sqrt{f_{ck}} b_o \cdot d \quad (\text{eq 11-34}) < V_{c2}$$

$$(c) \phi V_{c3} = .8 \cdot 4 \sqrt{f_{ck}} b_o \cdot d \quad (\text{eq 11-35}) < V_{c3}$$

$$\phi V_c = \text{Min}(\phi V_{c1}, \phi V_{c2}, \phi V_{c3}) \quad \text{ACI 318-05 CODE 11.12.2.1}$$
 $V_u \leq \phi V_c$, then OK

where

 β = ratio of long side to short side of the column, concentrated load or reaction area

 α_s = 40 for interior colimns

= 30 for edge columns

= 20 for corner columns

 b_o = perimeter of critical section

$$\text{Shade Ratio} = \frac{\text{Footing Area} - \text{Punching Area}}{\text{Footing Area}}$$

6.4.2 Check of Two-WayShear

	Ft.Name	F-3	Punching Area	12338.470 cm ²
	Pr.Name	1	Pile effect	.69 / 2
	Shape	Rectangle	ϕV_{c1}	555.159 tonf
	L.Comb.	1	ϕV_{c2}	570.957 tonf
	PI	400 mm	ϕV_{c3}	370.106 tonf
	Pw	400 mm	ϕV_c	370.106 tonf
	bo / d	3535.58 / 737.3 mm	Vu	39.533 tonf
	β_c / α_s	1 / 20	Result	OK

	Ft.Name	F-2	Punching Area	12934.510 cm ²
	Pr.Name	2	Pile effect	3.209 / 5
	Shape	Rectangle	ϕV_{c1}	714.318 tonf
	L.Comb.	1	ϕV_{c2}	1009.915 tonf
	PI	400 mm	ϕV_{c3}	476.212 tonf
	Pw	400 mm	ϕV_c	476.212 tonf
	bo / d	4549.2 / 737.3 mm	Vu	151.060 tonf
	β_c / α_s	1 / 40	Result	OK



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 37

6.5 PILE PUNCHING SHEAR FORCE

6.5.1 Pile Punching Shear Formula

 $V_u = \Sigma F_z \cdot \text{Shade Ratio}$

 (a) $\phi V_{c1} = .8 \cdot 2 \cdot (1 + 2/\beta_c) \sqrt{f_{ck}} b_o \cdot d$ (eq 11-33) < V_{c1}

 (b) $\phi V_{c2} = .8 \cdot 2 \cdot (1 + \alpha_s d / 2 b_o) \sqrt{f_{ck}} b_o \cdot d$ (eq 11-34) < V_{c2}

 (c) $\phi V_{c3} = .8 \cdot 4 \sqrt{f_{ck}} b_o \cdot d$ (eq 11-35) < V_{c3}
 $\phi V_c = \text{Min}(\phi V_{c1}, \phi V_{c2}, \phi V_{c3})$ ACI 318-05 CODE 11.12.2.1

 $V_u \leq \phi V_c$, then OK

where

 β = ratio of long side to short side of the column, concentrated load or reaction area

 $\alpha_s = 40$ for interior columns

= 30 for edge columns

= 20 for corner columns

 b_o = perimeter of critical section

 $\text{Shade Ratio} = \frac{\text{Footing Area} - \text{Punching Area}}{\text{Footing Area}}$

6.5.2 Check of Pile Punching Shear

	Ft.Name	F-3	Punching Area	10205.790 cm ²
	Pile No.	2	β_c / α_s	1 / 20
	Shape	Square	ϕV_{c1}	262.032 tonf
	L.Comb.	1	ϕV_{c2}	473.248 tonf
	PileName	PHC-12	ϕV_{c3}	174.688 tonf
	Diameter	300mm	ϕV_c	174.688 tonf
	bo	1668.77mm	Vu	100.246 tonf
	d	737.3mm	Result	OK

	Ft.Name	F-2	Punching Area	14006.290 cm ²
	Pile No.	5	β_c / α_s	1 / 20
	Shape	Square	ϕV_{c1}	371.662 tonf
	L.Comb.	1	ϕV_{c2}	509.792 tonf
	PileName	PHC-12	ϕV_{c3}	247.775 tonf
	Diameter	300mm	ϕV_c	247.775 tonf
	bo	2366.96mm	Vu	62.766 tonf
	d	737.3mm	Result	OK



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..

Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 38

7. DESIGN OF TIE-GIRDER

7.1 FORMULA

• Moment and Shear

• Reinforcement

- Shrinkage and temperature reinforcement ---- ACI CODE 7.12.2

 $As \geq fac \cdot b \cdot h$, fac = following

Area of shrinkage and temperature reinforcement shall provide at least the following ratio of reinforcement area to gross concrete area, but not less than 0.0014

0.0018 Slabs where Grade 40 or 50 deformed bars are used

0.0018 Slabs where Grade 60 deformed bars or welded wire reinforcement are used.....

(c) Slabs where reinforcement with yield stress exceeding 60,000 psi measured at a yield strain of 0.35 percent is used

- Required Reinforcement by Analysis

 $As \geq As_2$

- At every section of flexural members where tensile reinforcement is required

 $As \geq As_5 \geq As_4$ ---- ACI Eq (10-3)- The requirements of Eq (10-3) need not be applied, if every section As provided is at least one -third greater than that required by analysis ---- ACI CODE 10.5.3 $As_2 = \rho_{req} \cdot b \cdot d$ $As_3 = 1.333 \rho_{req} \cdot b \cdot d$ $As_4 = \frac{200}{f_y} \cdot b \cdot d$ $As_5 = \frac{3\sqrt{f_{ck}}}{f_y} \cdot b \cdot d$ $As_{max} = 0.75 \rho_b \cdot b \cdot d$ $\rho_b = 0.85 \times \beta_1 \times \frac{f_{ck}}{f_y} \times \frac{0.003 \times E_s}{0.003 \times E_s + f_y}$ Selected $As = \text{Max} (As_1 , As_2 , \text{Min} (As_3 , \text{Max} (As_4 , As_5)))$ **If Selected $As < \text{Using } As < As_{max}$, then OK!!**

Note : The reinforcement is calculated bases on the maximum moment under the foundation in each direction.

But, the 'ISO', 'OCT', 'HEX', 'COMB', 'TANK1' foundations are calculated as face pier

Where,

$$Rn = \frac{Mu}{\phi b d^2} , \phi = .85 , \rho_{req} = \frac{0.85 \cdot f_{ck}}{f_y} \times \left(1 - \sqrt{1 - \frac{2Rn}{0.85 f_{ck}}} \right)$$

• Shear

$$\phi V_c = \phi 2 \sqrt{f_{ck}} B_w d \quad [\text{ACI CODE 11.3.1.1 (11-3)}]$$

$$\phi V_s = \phi \frac{A_s f_y d}{s} \quad [\text{ACI CODE 11.5.7.2 (11-15)}]$$

$$\phi V_{smax} = \phi 8 \sqrt{f_{ck}} B_w d \quad [\text{ACI CODE 11.5.7.9}]$$

if $V_u < 0.5 \cdot \phi V_c$ then , $Asv_{req} = 0$

$$\text{if } V_u \geq 0.5 \cdot \phi V_c \text{ then , } Asv_{req} = \frac{(V_u - \phi V_c)s}{\phi f_y d} \geq 0.75 \sqrt{f_{ck}} \frac{b_w s}{f_y} \geq \frac{50 b_w s}{f_y} \quad [\text{ACI CODE 11.5.6.3 (11-13)}]$$

$$\phi V_n = \phi V_c + \phi V_s \quad [\text{ACI CODE 11.1.1.1 (11-2)}]$$

$$V_u \leq \phi V_n \rightarrow \text{OK} \quad [\text{ACI CODE 11.1.1.1 (11-1)}]$$

7.2 GEOMETRY AND MATERIALS

7.2.1 General

Unit(kgf/cm²,mm)

ϕ (Flexure)	ϕ (Shear)	f'c	fy1	fy2
.85	.8	280.00	4000.00	4000.00



Calculation Sheet of Foundation

Project Na. : 7.5 MW. Power Plant Stream..


Project No. : Revise F2-F3

Client : SAHAGREEN F...

Page 39

7.2.2 MATERIAL

Unit (mm , tonf , tonf-m)



7.3 MEMBER FORCE

» Sturcture 1

- ST-Beam

Unit (tonf , tonf-m)

L.Comb.	Ra	Rb	Ma	Mb	V _{max}	M _{max(-)}	M _{max(+)}
1	-1.44	1.44	-0.785	-0.785	-1.44	-0.785	1.015

7.4 REQUIRED REINFORCEMENT

» Sturcture 1

- ST-Beam

(cm²)

L.Comb.		As ₁	As ₂	As ₃	As ₄	As ₅	As _{select}	As _{used}	As _{max}	Result
1	Top	2.2	.4	.6	7.4	7	2.2	15.2	48.4	OK
	Bottom	2.2	.6	.8	7.4	7	2.2	15.2	48.4	OK

7.5 ONE WAY SHEAR

» Sturcture 1

- ST-Beam

(tonf , cm²)

L.Comb.	Vu	φVc	φVs	φVn	φVs _{max}	Asv _{use}	Asv _{req}	Result
1	1.44	15.482	12.432	27.915	61.929	1.425	0	OK

- Shear Reinforcement Space Check

» Sturcture 1

(mm)

Name	Using Space	Max Space	Result
ST-Beam	200	272.6	OK